PLANT MITIGATION MASTER LIST

GAS PROBES

- 1. Bleach Vats Area.
- 2. Sulfur Dioxide storage room.
- 3. Chlorine Cylinders fill station.
- 4. Chlorine Ton fill station.
- 5. Chlorine railcar #1.
- 6. Chlorine railcar #2.
- 7. Chlorine railcar #3. Out Of Service.

TANK LEVEL SYSTEM

- 1. Bleach Vat #1
- ` 2. Bleach Vat #2
 - 3. Bleach Storage Tank #1.
 - 4. Bleach Storage Tank #2.
- 5. Indoor 50% Caustic Tank.
- 6 & 7. Outdoor Caustic Tanks Out Of Service.

SCALE SHUTDOWN

- 1. Chlorine cylinder fill station.
- 2. Chlorine tons fill station #1.
- 3. Chlorine ton fill station #2.
- 4. Chlorine ton fill station #3.

AIR BFP SYSTEM

1. Back Flow System

VACUUM ALARM

1. V. Alarm

PANIC BUTTONS

- 1. Branch Manager back door.
- 2. Bleach Vats Area.
- 3. Warehouse Hallway.
- 4. Back door chlorine ton room.

VAT CONTROL SYSTEM

- 1. Bleach Vat #1
- 2. Bleach Vat #2

RAILCAR VALVE CLOSURE SYSTEM

- 1. R/C#1
- 2. R/C#2

CONFIRMATION OF OPERATION PLANT MITIGATION SYSTEMS

(Inspection Checklist)

Branch:	Milford						Week (Week Of:		1/9/12-1/13/12	
System Gas Probes	Monday		Tuesday		Wednesday		Thursday		Friday		
	0K 1 2	Defective	3 4	Defective	ОК 5	Defective	H. Charles and Street and St.	Defective	N. ASSESSMENT OF THE PARTY OF T	Defect	
Tank Level System	1 2	Defective	3 4	Defective	ок 5	Defective	ОК	Defective	ок	Defecti	
Scale Shutdown	OK 1,2,3,4	Defective	OK 1,2,3,4	Defective	OK 1,2,3,4	Defective	OK 1,2,3,4	Defective	OK 1,2,3,4	Defectiv	
Air BFP System	OK 1	Defective	ОК 1	Defective	ок 1	Defective	ОК 1	Defective	OK	Defective	
Vacuum Alarm	ок	Defective	ОК 1	Defective	ок	Defective	ОК	Defective	ок	Defective	
Panic Buttons	OK	Defective	OK 1	Defective	ок 2	Defective	OK 3	Defective	OK 4	Defective	
Vat Control System	OK 1	Defective	OK 2	Defective	OK	Defective	OK	Defective	ок	Defective	
Railcar VCS	OK	Defective	ок	Defective	ок	Defective	ОК	Defective	OK I	Defective	